

Product Certification Schedule

Schedule No: 083/003/039

Licensee: DUBAI CABLE COMPANY (PVT) LTD., P.O. BOX 11529, OLD ABU DHABI ROAD, JEBEL ALI, DUBAI, UNITED ARAB EMIRATES

Factory: DUBAI CABLE COMPANY (PVT) LTD., DUCAB-M2, P.O. BOX 9171, INDUSTRIAL CITY OF ABU DHABI, ABU DHABI, UNITED ARAB EMIRATES

Specification: BS 7846:2009 - Electric cables - Thermosetting insulated, armoured, fire resistant cables of rated voltage 600/1000 V, having low emission of smoke and corrosive gases when affected by fire - Specification

Type of Cable: Tables 4, 5 and 6 - Two-core, three-core and four-core 600/1000V cables with stranded copper conductors. Mica tape insulation over the conductor.

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Resistance to fire - Category F2. Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: DUCAB C BICC

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 09/07/2014

Signed for and on behalf of the British Approvals Service for Cables

Date 27/10/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004