

Type Approval Certificate Extension

This is to certify that Certificate No. 04/00011(E1) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER Dubai Cable Company (Private) Limited

PLACE OF PRODUCTION

P.O. Box 11529 Jebel Ali, Dubai United Arab Emirates (UAE)	P.O. Box 9171 Ducab M1 Musaffah, Abu Dhabi United Arab Emirates (UAE)	P.O. Box 9171 Ducab M2 Musaffah, Abu Dhabi United Arab Emirates (UAE)
--	--	--

DESCRIPTION Electric cables - 600/1000V armoured fire-resistant cables having thermosetting insulation and low emission of smoke and corrosive gases when affected by fire conforming to BS:7846 Category F2.

TYPES Fire Resistant to BS 7846:2000, Category F2.

SPECIFIED STANDARDS

Construction:	BS 7846:2000
Flame retardance:	BS EN 60332-1-2 and BS EN 50266-2-4
Fire resistance	BS 6387:1994 and BS 7846:2000
Smoke emission	BS EN 50268-2

APPLICATION Cabling in fixed installations in industrial areas, buildings and similar applications.

RANGE

Number of cores	Cross sectional area (mm ²)
2, 3 and 4	1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300 and 400
5	1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, and 70
7, 12, 19, 27, 37 and 48	1.5, 2.5 and 4

OPERATIONAL Maximum conductor temperature: 90°C.

Certificate No. 04/00011(E2)

Issue Date 3 March 2009

Expiry Date 8 February 2014

Sheet 1 of 2



A M Anderson
London Design Support Services
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS