


Loss Prevention Certification Board



This is to certify

DUBAI CABLE COMPANY (PRIVATE) LIMITED

Ducab-M1, Plot No. - 2D12,3D2,4D2,5D2, Sector - M41,
Industrial City of Abu Dhabi-1, Mussafah, Abu Dhabi, United Arab Emirates

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

Ducab - FR SCS

(refer to attached appendix for details)

has complied with the requirements of the following:

BS 6387: 1994 – Performance requirements for cables required to maintain circuit integrity under fire conditions.

IEC 60331-21: 1999 - Fire resisting characteristics of electric cables.

and achieved:

<0.5%HCI when tested in accordance with BS EN 50267-2-1: 1999 – Method of test for Gases evolved during combustion of electric cables.

>60% light transmittance when tested in accordance with BS EN 61034-2: 2005 – Measurement of smoke density of cables burning under defined conditions.

Certificate No. 782f

Issue No. 01

Date of Issue 09 August 2011

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of LPCB

Name: D HOARE



LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Global Ltd. and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 782f

DUBAI CABLE COMPANY (PRIVATE) LIMITED

Products

LPCB Ref. No.

Ducab - FR SCS

782f/01

| Nominal csa of conductor (mm ²) | Core construction (See note 1) | BS 6387 (See notes 2 - 4) | BS EN 50267-2-1 | BS EN 61034-2 | IEC 60331-21 (See Note 8) |
|---|-----------------------------------|------------------------------|-----------------|---------------|------------------------------|
| 1.5 | One | C, W, Z ⁽⁵⁾ | <0.5% HCl | >60% | Complies |
| 2.5 | One | C, W, Z ⁽⁵⁾ | <0.5% HCl | >60% | Complies |
| 4.0 | One | C, W, Z ^(6,7) | <0.5% HCl | >60% | Complies |
| 6.0 | One | C, W, Z ^(6,7) | <0.5% HCl | >60% | Complies |
| 10 | One | — | <0.5% HCl | >60% | Complies |
| 16 | One | — | <0.5% HCl | >60% | Complies |
| 25 | One | — | <0.5% HCl | >60% | Complies |
| 35 | One | — | <0.5% HCl | >60% | Complies |
| 50 | One | — | <0.5% HCl | >60% | Complies |
| 70 | One | — | <0.5% HCl | >60% | Complies |
| 95 | One | — | <0.5% HCl | >60% | Complies |
| 120 | One | — | <0.5% HCl | >60% | Complies |
| 150 | One | — | <0.5% HCl | >60% | Complies |
| 185 | One | — | <0.5% HCl | >60% | Complies |
| 240 | One | — | <0.5% HCl | >60% | Complies |
| 300 | One | — | <0.5% HCl | >60% | Complies |
| 400 | One | — | <0.5% HCl | >60% | Complies |
| 500 | One | — | <0.5% HCl | >60% | Complies |
| 630 | One | — | <0.5% HCl | >60% | Complies |

Uo/U 600/1000V

Continued

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of LPCB

Page 2 of 3

Date of Issue 09 August 2011

Issue No. 01

Name: D HOARE

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Global Ltd. and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 782f

DUBAI CABLE COMPANY (PRIVATE) LIMITED

Products

Ducab - FR SCS

LPCB Ref. No.

782f/01

- Note 1: Stranded conductor only.
- Note 2: Clauses 8 (Bending) and 9.1 & 9.2 (Impact) cannot be conducted due to the cable having only one core.
- Note 3: These cables also met category C,W,Z when tested for voltage rating 600/1000V which is not recognised by BS 6387.
- Note 4: Where a single cable is fitted in a conduit, only phase to earth voltage was applied.
- Note 5: To satisfy the requirement of BS 6387, testing for C, W & Z categories were conducted using a 20mm stainless steel conduit as the other metallic element.
- Note 6: To satisfy the requirement of BS 6387, testing for W & Z categories were conducted using a 20mm stainless steel conduit as the other metallic element.
- Note 7: To satisfy the requirement of BS 6387, testing for C category was conducted using a 38mm stainless steel conduit as the other metallic element.
- Note 8: These cables met the requirements of IEC 60331-21: 1999 when tested at a temperature of 950°C and at a voltage rating of 600V.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of LPCB

Name: D HOARE

Page 3 of 3

Date of Issue 09 August 2011

Issue No. 01

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Global Ltd. and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.