


Type Approval Certificate Extension

This is to certify that Certificate No. 01/00135(E3) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER	Dubai Cable Company (Private) Limited		
PLACE OF PRODUCTION	P.O. Box 11529 Jebel Ali, Dubai, United Arab Emirates (UAE)	P.O. Box 9171, Ducab M1, Musaffah, Abu Dhabi, United Arab Emirates (UAE)	P.O. Box 9171, Ducab M2, Musaffah, Abu Dhabi, United Arab Emirates (UAE)
DESCRIPTION	600/1000 V Armoured Electric Cables having Thermosetting Insulation and Flame Retardant Oversheath with Low Emission of Smoke and Corrosive Gases when affected by Fire		
TYPES	<u>CU/XLPE/LSF/AWA/LSF</u> Single core, copper conductor, XLPE insulated, LSF bedding, aluminium wire armour, LSF oversheathed cable. <u>CU/XLPE/LSF/SWA/LSF</u> Multi-core, Copper Conductor, XLPE Insulated, LSF bedding, galvanised steel wire armour, LSF oversheathed cable		
APPLICATION	Power and lighting circuits of fixed electrical installations in onshore residential, commercial and industrial locations		
SPECIFIED STANDARDS	BS 6724: 1997 IEC 60502-1: 2004		
Certificate No.	01/00135(E4)		
Issue Date	2 September 2011		
Expiry Date	2 September 2016		
Sheet	1 of 2		

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS


J. Sinclair
Aberdeen, Energy
Lloyd's Register EMEA

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

TYPES AND RATINGS

Voltage Rating 600/1000V. Maximum conductor temperature 90°C

Type	No. of Cores	Conductor size (mm ²)
Cu/XLPE/LSF/AWA/LSF	1	50 to 1000
Cu/XLPE/LSF/SWA/LSF	2, 3 & 4	1.5 to 400
Cu/XLPE/LSF/SWA/LSF	5	1.5 to 70
Cu/XLPE/LSF/SWA/LSF	7 to 48	1.5, 2.5 & 4

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. 01/00135(E4) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 01/00135(E3) to which this extension should be attached.

Certificate No. 01/00135(E4)
 Issue Date 2 September 2011
 Expiry Date 2 September 2016
 Sheet 2 of 2

Lloyd's Register EMEA
 71 Fenchurch Street, London EC3M 4BS

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



J. Sinclair
 Aberdeen, Energy
 Lloyd's Register EMEA