



Lloyd's  
Register

**COPY**

## Type Approval Certificate Extension

*This is to certify* that Certificate No. 94/00001 for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

<b>PRODUCER</b>	Dubai Cable Company (Private) Limited		
<b>PLACE OF PRODUCTION</b>	P.O. Box 11529 Ducab Jebel Ali, Dubai United Arab Emirates (UAE)	P.O. Box 9171 Ducab M1 Musaffah, Abu Dhabi United Arab Emirates (UAE)	P.O. Box 9171 Ducab M2 Musaffah, Abu Dhabi United Arab Emirates (UAE)
<b>DESCRIPTION</b>	Flame retardant single and multi-core power cables heat resistant PVC insulated.		
<b>TYPE</b>	H07V-U, H07V-R, H07V-K as per BS EN 50525-2-31  6181Y, 6192Y, 6193Y, 6241Y, 6242Y, 6243Y 3192A, 3182A, 3183A, 3184A and 3185A as per BS 6004		
<b>SPECIFIED STANDARDS</b>	BS 6004:2012 BS EN 50525-2-31:2011 BS EN 60332-1-2:2004		
<b>APPLICATION</b>	Power and lighting circuits for industrial and residential installations		
<b>RATING</b>	Type H07V-U, H0V-R, H07V-K voltage rating 450/750V Voltage rating 300/500V for all others		
<b>Certificate No.</b>	94/00001(E6)		
<b>Issue Date</b>	30 May 2014		
<b>Expiry Date</b>	4 January 2019		
<b>Sheet</b>	1 of 2		

M Malone  
Aberdeen Energy Compliance Engineering  
Lloyd's Register EMEA

Lloyd's Register EMEA  
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

RANGE

Conductor Size (mm <sup>2</sup> )	Number of Cores
1.5, 2.5, 4, 6, 10, 16, 25 & 35	1, 2, 3, 4 & 5
50, 70, 95, 120, 150, 185, 240	1
300, 400, 500 & 630	1

OPERATIONAL  
LIMITATIONS

Maximum conductor temperature for continuous operation: 85<sup>o</sup> C.

*"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."*

*The Design Appraisal Document No. O-31324(01) and its supplementary Type Approval Terms and Conditions form part of this Certificate.*

**All other details remain as on the previous Certificate No. 94/00001(E5) to which this extension should be attached.**

Certificate No. 94/00001(E6)  
Issue Date 30 May 2014  
Expiry Date 4 January 2019  
Sheet 2 of 2



M Malone  
Aberdeen Energy Compliance Engineering  
Lloyd's Register EMEA

Lloyd's Register EMEA  
71 Fenchurch Street, London EC3M 4BS